SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA 22.2, #8 TUV APPROVED: EN60950

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 30 AMP/55°C, 80 VDC

LINE FREQUENCY: DC

MAXIMUM LEAKAGE CURRENT, EACH LINE TO GROUND:

N/A mA@ 120V 60Hz N/A mA@ 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +55°C @ RATED CURRENT, I_r. IN AN AMBIENT, T_0, HIGHER THAN 55°C, THE MAXIMUM OPERATING CURRENT, I_0, IS AS FOLLOWS: I_0 = I_r $\sqrt{85-T_0}$

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES I_r FOR 8 SECONDS

TEST SPECIFICATIONS:

INDUCTANCE: 0.701mH NDMINAL

CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

CATALOG # 30DCF6

APPRVD. DDMMMYY

11MARO3

EC#

0631-0093-03

LINE TO GROUND: 0.093 µF ±20% LINE TO LINE: 2.024 µF ±20%

DISCHARGE RESISTOR: 0.165Ma L/G AND L/L I.R.


NO DISCHARGE RESISTOR: 6000M (MIN.) @ 100VDC, 20°C AND 50% RH


RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 2250 VDC FOR 1 MINUTE LINE TO LINE: 1450 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.





50A- 50A(MINIMUM) INSERTION LOSS											
FREQUENCY MHz	.01	. 05	0.1	. 15	0.5	1	3	5	10	30	
COMMON dB		4	15	23	47	59	64	56	44	36	
DIFF. dB	7	22	28	31	32	59	56	51	41	28	

THIRD ANGLE PROJECTION			
TIVILECE UTHER	DWICE CE	ECTETED	

UNLESS OTHERWISE SPECIFIED, TOLERANCE TO BE ±.025 MATERIAL & FINISH: AS SUPPLIED

This document	is proprietary to CORCOM INC.
and is not to	be reproduced nor used for
	purposes except on CORCOM'S
prior written	consent.

tyco	Electronics	#corcom		
/	844 E. ROCKLAND RD.	LIBERTYVILLE IL 60048		

POWER LINE FILTER

	CAD FILE: G:	\CD\30DCF603	TYCO # 0-1609074-3	
٠.	SCALE: NITS	DATE:	CATALOG NO.	REV.
	1/1/2	10-30-00	a a p d Fra	
	DRW. BY:	ORIG:	30DCF6	- 3
	PJ0	PJ0		