## Dantherm Air Handling A/S

# Operating instructions

ebm-papst Mulfingen GmbH & Co. KG

Bachmühle 2 D-74673 Mulfingen Phone +49 (0) 7938 81-0 Fax +49 (0) 7938 81-110 info1@de.ebmpapst.com www.ebmpapst.com

### **CONTENTS**

1. SAFETY REGULATIONS AND NOTES	1
1.1 Levels of hazard warnings	1
1.2 Staff qualification	1
1.3 Basic safety rules	1
1.4 Electrical voltage	1
1.5 Safety and protective functions	2
1.6 Electromagnetic radiation	2
1.7 Mechanical movement	2
1.8 Emission	2
1.9 Hot surface	2
1.10 Transport	2
1.11 Storage	2
1.12 Disposal	2
2. PROPER USE	3
3. TECHNICAL DATA	4
3.1 Product drawing	4
3.2 Nominal data	5
3.3 Technical features	5
3.4 Mounting data	5
3.5 Transport and storage conditions	5
4. CONNECTION AND START-UP	6
4.1 Connecting the mechanical system	6
4.2 Connecting the electrical system	6
4.3 Connection via plug	6
4.4 Connection screen	7
4.5 Checking the connections	8
4.6 Switch on device	8
4.7 Switching off the device	8
5. MAINTENANCE, MALFUNCTIONS, POSSIBLE CAUSES AND REMEDIES	8
5.1 Cleaning	9
5.2 Safety test	9

### 1. SAFETY REGULATIONS AND NOTES

Please read these operating instructions carefully before starting to work with the device. Observe the following warnings to prevent malfunctions or physical damage to both property and people.

These operating instructions are to be regarded as part of this device. If the device is sold or transferred, the operating instructions must accompany it.

These operating instructions may be duplicated and forwarded for information about potential dangers and their prevention.

### 1.1 Levels of hazard warnings

These operating instructions use the following hazard levels to indicate potentially hazardous situations and important safety regulations:



#### DANGER

Indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury. Compliance with the measures is mandatory.

#### WARNING

Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury. Exercise extreme caution while working.

### **CAUTION**

Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury or damage of property.

#### NOTE

A potentially harmful situation can occur and, if not avoided, can lead to property damage.

### 1.2 Staff qualification

The device may only be transported, unpacked, installed, operated, maintained and otherwise used by qualified, trained and authorised technical staff.

Only authorised specialists are permitted to install the device, to carry out a test run and to perform work on the electrical installation.

### 1.3 Basic safety rules

Any safety hazards stemming from the device must be re-evaluated once it is installed in the end device.

Observe the following when working on the unit:

⇒ Do not make any modifications, additions or conversions to the device without the approval of ebm-papst.

### 1.4 Electrical voltage

- Check the electrical equipment of the device at regular intervals, refer to chapter 5.2 Safety test.
- ⇒ Replace loose connections and defective cables immediately.

### WARNING

Terminals and connections have voltage even with a unit that is shut off

Electric shock

→ Wait five minutes after disconnecting the voltage at all poles before opening the device.

### CAUTION

If control voltage is applied or a speed setpoint is stored, the motor automatically restarts, e.g. after a power failure. Danger of injury





### R1G225-AG15-11

### Dantherm Air Handling A/S

# Operating instructions

- → Keep out of the danger zone of the device.
- → When working on the device, switch off the mains supply voltage and secure the latter from being switched on again.
- → Wait until the device stops.
- → After working on the device, remove any used tools or other objects from the device.

### 1.5 Safety and protective functions



### **DANGER**

### Missing safety device and non-functioning safety device

If there is no safety device, you could be seriously injured, for example if you reach into the running device or your hands are sucked into it.

- Operate the device only with a fixed and isolating safety protection and a fixed guard grille. The guard must withstand the kinetic energy of a fan blade detaching at maximum speed.
- → The device is a built-in component. You, the owner/ operator, are responsible for providing adequate protection for the device.
- → Shut down the device immediately if you detect a missing or ineffective protective feature.

### 1.6 Electromagnetic radiation

Interference from electromagnetic radiation is possible, e.g. in conjunction with open and closed-loop control devices.

If unacceptable emission intensities occur when the fan is installed, appropriate shielding measures have to be taken by the user.

### NOTE

Electrical or electromagnetic interferences after integrating the device in installations on the customer's

→ Verify that the entire setup is EMC compliant.

### 1.7 Mechanical movement



### **DANGER**

### Rotating device

Body parts that come into contact with the rotor and impeller can be injured.

- → Secure the device against accidental contact.
- → Before working on the system/machine, wait until all parts have come to a standstill.

### **WARNING**

### Rotating device

Long hair, loose items of clothing and jewellery could become entangled and pulled into the device. You could be injured.

- → Do not wear any loose clothing or jewellery while working on rotating parts.
- → Protect long hair by wearing a cap.

### 1.8 Emission

### WARNING

Depending on the installation and operating conditions, a sound pressure level greater than 70 dB(A) may arise. Danger of noise-induced hearing loss

- → Take appropriate technical safety measures.
- → Protect operating personnel with appropriate safety equipment, e.g. hearing protection.
- $\ensuremath{\rightarrow}$  Also observe the requirements of local agencies.

### 1.9 Hot surface



### **CAUTION**

## High temperature at the electronics enclosure

Danger of burn injuries

→ Ensure that sufficient protection against accidental contact is provided.

### 1.10 Transport

### **NOTE**

### Transport of device

- → Transport the device in its original packaging only.
- → Secure the device so that it does not slip, e.g. by using a clamping strap.

### 1.11 Storage

- Store the device, partially or fully assembled, in a dry and weatherproof manner in the original packing in a clean environment.
- Protect the device from environmental impacts and dirt until the final installation.
- ⇒ We recommend storing the device for a maximum up to one year to guarantee proper operation and longest possible service life.
- ⇒ Even devices explicitly suited for outdoor use are to be stored as described prior to being commissioned.
- ⇒ Maintain the storage temperature, see chapter 3.5 Transport and storage conditions.

### 1.12 Disposal

When disposing of the device, please comply with all relevant requirements and regulations applicable in your country.





### R1G225-AG15-11

Dantherm Air Handling A/S

# Operating instructions

### 2. PROPER USE

The device is exclusively designed as a built-in device for moving air according to its technical data.

Any other or secondary use is deemed improper and constitutes a misuse of the device.

Installations on the customer's side must meet the mechanical, thermal and service life-related stresses that can occur.

### Proper use also includes:

- Use the device in DC power systems only.
- Moving air with a density of 1.2 kg/m³.
- Using the device in accordance with the permitted ambient temperature, see chapter 3.5 Transport and storage conditions and chapter 3.2 Nominal data.
- Operating the device with all protective features in place.
- Minding the operating instructions.

### Improper use

Using the device in the following ways is particularly prohibited and may cause hazards:


- Operating the device with an imbalance, e.g. caused by dirt deposits or icing.
- Moving air that contains abrasive particles.
- Moving highly corrosive air, e.g. salt spray mist. Exceptions are devices that are intended for salt spray mist and protected accordingly.
- Moving air that contains dust pollution, e.g. suctioning off saw dust.
- Operating the device close to flammable materials or components.
- Operating the device in an explosive atmosphere.
- Using the device as a safety component or for taking on safetyrelated functions.
- Operation with completely or partially disassembled or modified protective features.
- In addition, all application options that are not listed under proper use.






## 3. TECHNICAL DATA

## 3.1 Product drawing





All measures have the unit mm

Z	View Z snown magnitied
1	Accessory part: Inlet nozzle 96358-2-4013 not included in scope of delivery
2	Depth of screw max. 6 mm
3	Connection line PVC AWG20 with connector housing 4-pole Tyco 172159-1, 4x plug pin Tyco 170360-3
3.1	+ (red)
3.2	- (blue)
3.3	PWM (black)
3.4	Tach (white)
3.5	Polarising rib



### 3.2 Nominal data

Motor	M1G074-CF
Nominal voltage / VDC	48
Nominal voltage	36 49
range / VDC	
Type of data definition	fa
Speed / min-1	2850
Power input / W	115
Current draw / A	2.7
Min. ambient temperature	-25
/ °C	
Max. ambient	60
temperature	
/ °C	

ml = Max. load  $\cdot$  me = Max. efficiency  $\cdot$  fa = Running at free air

 $cs = Customer specs \cdot cu = Customer unit$ 

Subject to alterations

### 3.3 Technical features

Mass	1.8 kg
Size	225 mm
Surface of rotor	Coated in black
Material of impeller	PA plastic
Number of blades	7
Direction of rotation	Clockwise, seen on rotor
Type of protection	IP 44
Insulation class	"B"
Humidity class	F3-1
Mounting position	Any
Operation mode	S1
Motor bearing	Ball bearing
Technical features	- Control input 0-10 VDC / PWM
	- Tach output
	- Motor current limit
	- Soft start
Electrical leads	With plug
Motor protection	Reverse polarity and locked-rotor
	protection
Cable exit	Variable
Product conforming	EN 60950-1
to standard	
Approval	UL 1004-1; CSA C22.2 Nr.77



For cyclic speed loads, note that the rotating parts of the device are designed for maximum one million load cycles. If you have specific questions, contact ebm-papst for support.

### 3.4 Mounting data

For depth of screw, see chapter 3.1 Product drawing

Secure the mounting screws against accidentally coming loose (e.g. by using self-locking screws).

Strength class for	8.8
mounting screws	

You can obtain additional mounting data from the product drawing if necessary.

### 3.5 Transport and storage conditions

⇒ Use the device in accordance with its protection type.

Max. permissible ambient motor temp.	+80 °C
(transp./ storage)	
Min. permissible	-40 °C
ambient motor temp.	
(transp./storage)	





## Dantherm Air Handling A/S

# Operating instructions

### 4. CONNECTION AND START-UP

### 4.1 Connecting the mechanical system



### **CAUTION**

# Cutting and crushing hazard when removing the fan from the packaging



- → Carefully hold the impeller to remove the device from its packaging. Make sure to avoid any shock.
- → Wear safety shoes and cut-resistant safety gloves.
- Check the device for transport damage. Damaged devices must no longer be installed.
- ⇒ Install the undamaged device according to your application.

### 4.2 Connecting the electrical system

### **CAUTION**

### **Electrical voltage**

The fan is a built-in component and features no electrically isolating switch.

- → Only connect the fan to circuits that can be switched off with an all-pole separating switch.
- → When working on the fan, you must switch off the installation/machine in which the fan is installed and secure it from being switched on again.

### NOTE

### Water penetration into leads or wires

Water enters at the cable end on the customers side and can damage the device.

Make sure that the cable end is connected in a dry environment



Operate the device with a safely isolated power pack.

### 4.2.1 Prerequisites

- Check whether the data on the type plate agree with the connection data.
- Before connecting the device, ensure that the supply voltage matches the operating voltage of the device.
- Only use cables designed for current according to the type plate. For determining the cross-section, follow the basic principles in accordance with EN 61800-5-1. The protective earth must have a cross-section equal to or greater than the outer conductor cross-section.

We recommend the use of 105°C cables. Ensure that the minimum cable cross-section is at least AWG26/0.13 mm².

### 4.2.2 Idle current



Because of the EMC filter integrated for compliance with EMC limits (interference emission and interference immunity), idle currents in the mains cable can be measured even when the motor is at a standstill and the mains voltage is switched on.

### 4.3 Connection via plug


### 4.3.1 Establish supply connections

- ⇒ Check the PIN assignment of your connector.
- ⇒ Connect the panel connector and mating connector.
- ⇒ Ensure that the connector is locked in correctly.





### 4.4 Connection screen



No.	Conn.	Designation	Colour	Function / assignment
1	1	Un +48 VDC	red	Power supply 48 VDC, maximum ripple 3.5 %
1	2	PWM / lin	black	PWM / lin. Control input, 0-10 V
1	3	Tach	white	Speed monitoring output, 3 pulses per revolution, Isink max = 10 mA
1	4	GND	blue	Reference ground



### 4.5 Checking the connections

- ⇒ Make sure that the power is off (all phases).
- ⇒ Secure it from being switched on again.
- Check that the mating connector is correctly locked into the panel connector.
- Check that the mating connector is correctly crimped to the connection line.

### 4.6 Switch on device

The device may only be switched on if it has been installed properly and in accordance with its intended use, including the required safety mechanisms and professional electrical connection. This also applies for devices which have already been equipped with plugs and terminals or similar connectors by the customer.



### WARNING Hot motor housing

Fire hazard

- → Ensure that no combustible or flammable materials are located close to the fan.
- Inspect the device for visible external damage and the proper function of the protective features before switching it on.
- Check the air flow paths of the fan for foreign objects and remove any that are found.
- ⇒ Apply the nominal voltage to the voltage supply.
- Start the device by changing the input signal.

### 4.7 Switching off the device

Switching off the device during operation:

- ⇒ Switch off the device via the control input.
- Do not switch the motor (e.g. in cyclic operation) on and off via power supply.

Switching off the device for maintenance work:

- ⇒ Switch off the device via the control input.
- Do not switch the motor (e.g. in cyclic operation) on and off via power supply.
- ⇒ Disconnect the device from the supply voltage.

# 5. MAINTENANCE, MALFUNCTIONS, POSSIBLE CAUSES AND REMEDIES

Do not perform any repairs on your device. Return the device to ebmpapst for repair or replacement.

#### WARNING

Terminals and connections have voltage even with a unit that is shut off

Electric shock

→ Wait five minutes after disconnecting the voltage at all poles before opening the device.

#### CAUTION

If control voltage is applied or a speed setpoint is stored, the motor automatically restarts, e.g. after a power failure. Danger of injury

- → Keep out of the danger zone of the device.
- → When working on the device, switch off the mains supply voltage and secure the latter from being switched on again.
- → Wait until the device stops.
- → After working on the device, remove any used tools or other objects from the device.



If the device remains out of use for some time, e.g. when in storage, we recommend switching the device on for at least two hours to allow any condensate to evaporate and to move the bearings.

Malfunction/error	Possible cause	Possible remedy
Impeller running	Imbalance in rotating	Clean the device; if
roughly	parts	imbalance is still
		evident after
		cleaning, replace the
		device.
		If you have
		attached any weight
		clips during cleaning,
		make sure to
		remove them
		afterwards.
Motor does not turn	Mechanical blockage	Switch off, de-
		energise, and
		remove mechanical
		blockage.
	Mains supply	Check mains supply
	voltage faulty	voltage,
		restore power
		supply,
		apply control signal.
	Faulty connection	De-energise, correct
		connection, see
		connection diagram.



### R1G225-AG15-11

## Dantherm Air Handling A/S

# Operating instructions

Overtemperature of	Insufficient cooling	Improve cooling. Let
electronics/motor		the device cool
		down.
		To reset the error
		message, switch off
		the mains supply
		voltage for a min. of
		25 s and switch it on
		again.
	Ambient temperature	Reduce the ambient
	too high	temperature.
		Reset by reducing
		control input to 0.
	Unacceptable	Correct the operating
	operating point	point. Let the device
		cool down.

Condensate discharge holes for clogging, as necessary	At least every 6 months	Open bore holes
---	----------------------------	-----------------



If you have any other problems, contact ebm-papst.

### 5.1 Cleaning

### NOTE

### Damage to the device during cleaning.

Malfunction possible

- → Do not clean the device using a water jet or high-pressure washer
- → Do not use any cleaners containing acids, bases or solvents.
- → Do not use any pointed or sharp-edged objects to clean.

### 5.2 Safety test

What has to be tested?	How to test?	Frequency	Which measure?
Check the	Visual inspection	At least every	Repair or
protective	Viodai iliopootion	6 months	replacement of
casing against		o montro	the device
accidental			110 401100
contact for			
damage and to			
ensure that it is			
intact			
Check the	Visual inspection	At least every	Replacement
device for		6 months	of the device
damage to			
blades and			
housing			
Mounting the	Visual inspection	At least every	Fasten
connection lines		6 months	
Check the	Visual inspection	At least every	Replace wires
insulation of		6 months	
the wires for			
damage			
Impeller for	Visual inspection	At least every	Clean or
wear/deposits/		6 months	replace impeller
corrosion and			
damage			



