# XCSL564B3



$\mathbf{n}_{I}$	2	ın
IVI	$\boldsymbol{\sigma}$	

Device short name	XCSL
Enclosure type	Enclosure water resistant indoor/outdoor Enclosure dustproof indoor/outdoor Enclosure ice/sleet proof indoor/outdoor

### Complementary

Line Rated Current	10 A	
[Us] rated supply voltage	24 V DC	_
Actuator	Key	
Contact operation	Slow-break, break before make	
Contacts type and composition	1 NC 2 NO staggered	
Depth	1.73 in	
Enclosure material	Metal	
Height	7.64 in	
Installation direction	Left electromagnet connection Right actuator supply	
Key locking position	Front	
Locking options description	With locking of actuator, unlocking by key operated lock	
Number of poles	3	
Permissible voltage	<= 300 V AC	
Pilot light	LED orange	

### **Environment**

ambient air temperature for operation	-13158 °F	_
IP degree of protection	IP67	
NEMA degree of protection	NEMA 1/2/3/4/12	
product certifications	CE UL listed file E164353 CCN NKCR CSA LR4408794 class 3211 03	

### Offer Sustainability

Green Premium product	Green Premium product
Compliant - since 1136 - Schneider Electric declaration of conformity	Compliant - since 1136 - Schneider Electric declaration of conformity
Reference not containing SVHC above the threshold	Reference not containing SVHC above the threshold
Need no specific recycling operations	Need no specific recycling operations
WARNING: This product can expose you to chemicals including:	WARNING: This product can expose you to chemicals including:
Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and	e Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and
Di-isodecyl phthalate (DIDP), which is known to the State	eDi-isodecyl phthalate (DIDP), which is known to the State of California to cause birth

of California to cause birth defects or other reproductive defects or other reproductive harm. harm. For more information go to www.p65warnings.ca.gov

For more information go to www.p65warnings.ca.gov

## Contractual warranty

Warranty period	18 months	