ZCKE629

Green Premium™

Main

Range of product	OsiSense XC
Series name	Standard format
Product or component type	Limit switch head
Device short name	ZCKE
Head type	Plunger head
Product compatibility	XCKJ
Associated body	ZCKJ1
	ZCKJ11
	ZCKJ11H29
	ZCKJ11H7
	ZCKJ1H29
	ZCKJ1H7
	ZCKJ2
	ZCKJ21
	ZCKJ21H29
	ZCKJ21H7
	ZCKJ2H29
	ZCKJ2H7
	ZCKJ4
	ZCKJ41
	ZCKJ41H29
	ZCKJ41H7
	ZCKJ4H29
	ZCKJ4H7
	ZCKJ5
	ZCKJ5H29
	ZCKJ5H7
	ZCKJ6
	ZCKJ6H29
	ZCKJ6H7
	ZCKJ7
	ZCKJ7H29
	ZCKJ7H7
	ZCKJ8
	ZCKJ8H29
	ZCKJ8H7
	ZCKJ9
	ZCKJ9H29
	ZCKJ9H7
	ZCKJD31
	ZCKJD31H29
	ZCKJD31H7
	ZCKJD35
	ZCKJD35H29
	ZCKJD35H7
	ZCKJD37
	ZCKJD37H29
	ZCKJD37H7
	ZCKJD39
	ZCKJD39H29
	ZCKJD39H7
Movement of operating head	Linear
Type of operator	Roller plunger spring return metal (with protective boot)
Type of approach	Lateral approach 2 directions

Complementary

Switch actuation	By 30° cam
Positive opening	With
Head material	Metal

Schneider Electric

Environment

ambient air temperature for operation	-13...158 °F (-25...70 °C)
ambient air temperature for storage	-40...158 °F (-40...70 °C)
environmental characteristic	Standard environment

Offer Sustainability

Green Premium product	Green Premium product
Compliant - since 1014 - Schneider Electric declaration of conformity	Compliant - since 1014 - Schneider Electric declaration of conformity
Reference not containing SVHC above the threshold	Reference not containing SVHC above the threshold
Need no specific recycling operations	Need no specific recycling operations
WARNING: This product can expose you to chemicals including:	WARNING: This product can expose you to chemicals including:
Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and	Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and
Di-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm.	Di-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm.
For more information go to www.p65warnings.ca.gov	For more information go to www.p65warnings.ca.gov

Contractual warranty

Warranty period	18 months