XY2CH33010H7





Main

| Range of product | Preventa XY2 |
|---------------------------|---|
| Product or component type | Latching emergency stop rope pull switch |
| Device short name | XY2CE |
| Housing colour | Blue |
| Overvoltage category | Class I conforming to EN/IEC 61140 Class I conforming to NF C 20-030 |

Complementary

| o o mpromormany | |
|--|---|
| Local signalling | Without pilot light |
| Number of cables | 1 |
| Trigger cable maximum length | 49.21 ft (15 m) |
| Body material | Zamak |
| Cover material | Stainless steel |
| Reset | By booted push-button |
| Contacts type and composition | 1 NC + 1 NO |
| Contact operation | Snap action |
| Trigger cable anchor point | RH or LH side |
| Connections - terminals | Screw clamp terminal 1 x 0.52 x 1.5 mm ² Screw clamp terminal 1 x 0.342 x 0.75 mm ² |
| Tightening torque | 7.0810.62 lbf.in (0.81.2 N.m) |
| Cable entry number | 3 tapped entry Pg 13.5 cable gland |
| Safety level | Can reach category 4 with the appropriate monitoring system and correctly wired conforming to EN/ISO 13849-1 Can reach PL = e with the appropriate monitoring system and correctly wired conforming to EN/ISO 13849-1 Can reach SIL 3 with the appropriate monitoring system and correctly wired conforming to EN/IEC 61508 |
| Safety reliability data | B10d = 4000000 with value given for a life time of 20 years limited by mechanical or contact wear conforming to IEC 60947-5-5 |
| Marking | CE |
| Mechanical durability | 800000 cycles |
| Distance between cable supports | 16.4 ft (5 m) |
| [le] rated operational current | 3 A at 240 V AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A 0.27 A at 250 V DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A |
| [Ithe] conventional enclosed thermal current | 10 A |
| [Ui] rated insulation voltage | 500 V (degree of pollution: 3) conforming to EN/IEC 60947-1 300 V (degree of pollution: conforming to UL 508 |
| [Uimp] rated impulse withstand voltage | 6 kV conforming to EN/IEC 60947-1 |
| Positive opening | With conforming to EN/IEC 60947-5-1 |
| Resistance across terminals | <= 25 MOhm conforming to NF C 93-050 method A <= 25 MOhm conforming to EN/IEC 60255-7 category 3 |
| Short-circuit protection | 10 A by gG cartridge fuse conforming to EN/IEC 60269 |
| Terminals description ISO n°1 | (13-14)NO (21-22)NC |
| Product weight | 3.2 lb(US) (1.45 kg) |

Environment



| standards | EN/IEC 60947-5-1 EN/IEC 60947-5-5 EN/ISO 13850 Machinery directive 2006/42/EC CSA C22.2 No 14 Work equipment directive 2009/104/EC |
|---------------------------------------|---|
| product certifications | UL category NISD emergency stop devices CCC |
| protective treatment | TC |
| ambient air temperature for operation | -13158 °F (-2570 °C) |
| ambient air temperature for storage | -40158 °F (-4070 °C) |
| vibration resistance | 10 gn (f = 10300 Hz) conforming to EN/IEC 60068-2-6 |
| shock resistance | 50 gn 11 ms conforming to EN/IEC 60068-2-27 |
| IP degree of protection | IP66 conforming to IEC 60529 |

Offer Sustainability

| Green Premium product | Green Premium product |
|--|---|
| Compliant - since 1004 - Schneider Electric declaration of conformity | Compliant - since 1004 - Schneider Electric declaration of conformity |
| Reference not containing SVHC above the threshold | Reference not containing SVHC above the threshold |
| Available | Available |
| Need no specific recycling operations | Need no specific recycling operations |
| WARNING: This product can expose you to chemicals including: | WARNING: This product can expose you to chemicals including: |
| Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and | Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and |
| Di-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm. | eDi-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm. |
| For more information go to www.p65warnings.ca.gov | For more information go to www.p65warnings.ca.gov |

Contractual warranty

| | • |
|-----------------|-----------|
| | |
| Warranty period | 18 months |
| | |
| | |

