# XCKJ110513DSA9



#### Main

Range of product	OsiSense XC
Series name	Standard format
Product or component type	Limit switch
Device short name	XCKJ
Sensor design	-
Body type	Plug-in body
Head type	Rotary head
Material	Metal
Body material	Zamak
Head material	Zamak
Fixing mode	By the body
Movement of operating head	Rotary
Type of operator	Spring return roller lever metal
Type of approach	Lateral approach 1 or 2 programmable direction
Cable entry	1 entry tapped for Pg 13.5 cable gland, cable outer diameter: 0.350.47 in (912 mm)
Number of poles	1
Contacts type and composition	1 C/O
Contact operation	Snap action

### Complementary

By 30° cam Screw-clamp terminals, clamping capacity: 1 x 0.752 x 1.5 mm²  Zb  1  Without  2.21 lbf.in (0.25 N.m)  4.92 ft/s (1.5 m/s)  3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A 0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
Zb  1  Without  2.21 lbf.in (0.25 N.m)  4.92 ft/s (1.5 m/s)  3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A  0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
Mithout  2.21 lbf.in (0.25 N.m)  4.92 ft/s (1.5 m/s)  3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A  0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
Without  2.21 lbf.in (0.25 N.m)  4.92 ft/s (1.5 m/s)  3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A  0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
2.21 lbf.in (0.25 N.m) 4.92 ft/s (1.5 m/s) 3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A 0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
4.92 ft/s (1.5 m/s) 3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A 0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
3 A at 240 V, AC-15, A300 conforming to EN/IEC 60947-5-1 appendix A 0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A 10 A
0.27 A at 250 V, DC-13, Q300 conforming to EN/IEC 60947-5-1 appendix A
500 V degree of pollution 3 conforming to IEC 60947-1 300 V conforming to UL 508 300 V conforming to CSA C22.2 No 14
<= 25 MOhm conforming to IEC 60255-7 category 3
6 kV conforming to IEC 60664 6 kV conforming to IEC 60947-1
10 A by gG cartridge fuse
5000000 cycles, DC-13, inductive load type, 120 V, 4 W, operating rate: <= 60 cyc/mn, oad factor: 0.5 conforming to IEC 60947-5-1 appendix C 5000000 cycles, DC-13, inductive load type, 24 V, 10 W, operating rate: <= 60 cyc/mn, oad factor: 0.5 conforming to IEC 60947-5-1 appendix C 5000000 cycles, DC-13, inductive load type, 48 V, 7 W, operating rate: <= 60 cyc/mn, oad factor: 0.5 conforming to IEC 60947-5-1 appendix C
30000000 cycles
1.69 in (43 mm)
3.31 in (84 mm)
1.42 in (36 mm)
1.08 lb(US) (0.49 kg)
(11-12)NC (13-14)NO

### **Environment**

shock resistance	50 gn (duration = 11 ms) conforming to IEC 60068-2-27
vibration resistance	25 gn (f = 10500 Hz) conforming to IEC 60068-2-6
IP degree of protection	IP66 conforming to IEC 60529
IK degree of protection	IK07 conforming to EN 50102
overvoltage category	Class I conforming to NF C 20-030 Class I conforming to IEC 61140
ambient air temperature for operation	-13158 °F (-2570 °C)
ambient air temperature for storage	-40158 °F (-4070 °C)
protective treatment	TC
product certifications	CCC CSA UL
standards	CENELEC EN 50041 EN 60204-1 EN 60947-5-1 IEC 60204-1 IEC 60947-5-1 UL 508 CSA C22.2 No 14

## Offer Sustainability

Not Green Premium product	Not Green Premium product
Will be Compliant on 4Q2013	Will be Compliant on 4Q2013 Will be Compliant on 4Q2013
WARNING: This product can expose you to chemicals including:	WARNING: This product can expose you to chemicals including:
Diisononyl phthalate (DINP), which is known to the Stat of California to cause cancer, and	e Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and
Di-isodecyl phthalate (DIDP), which is known to the Star of California to cause birth defects or other reproductive harm.	teDi-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm.
For more information go to www.p65warnings.ca.gov	For more information go to www.p65warnings.ca.gov

## Contractual warranty

Warranty period 18 months
---------------------------

