XU2M18AP20D



Main

Range of product	OsiSense XU
Series name	Application material handling
Electronic sensor type	Photo-electric sensor
Sensor name	XU2
Sensor design	Cylindrical M18
Detection system	Thru beam
Material	Metal
Line of sight type	Axial
Type of output signal	Analogue Discrete
Supply circuit type	DC
Wiring technique	3-wire
Discrete output type	PNP
Discrete output function	1 NO
Analogue output range	420 mA
Electrical connection	1 male connector M12, 4 pins
Product specific application	-
Emission	Infrared thru beam
[Sn] nominal sensing distance	164.04 ft (50 m) thru beam

Complementary

Nickel plated brass
PMMA
229.66 ft (70 m)
Solid state
With analogue output
Breaking test (transmitter)
1 LED (green) supply on 1 LED (yellow) operation
1224 V DC with reverse polarity protection
1030 V DC
<= 100 mA (overload and short-circuit protection)
<= 30 Hz
<= 1.5 V (closed state)
<= 55 mA (no-load)
<= 50 ms
<= 15 ms
<= 15 ms
Sensitivity adjustment
0.71 in (18 mm)
3.74 in (95 mm)
0.34 lb(US) (0.155 kg)
Transmitter + receiver

Environment

product certifications	CE	
	CSA	
	UL	
ambient air temperature for operation	-13131 °F (-2555 °C)	

ambient air temperature for storage	-40158 °F (-4070 °C)
vibration resistance	25 gn, amplitude = +/- 2 mm (f = 1055 Hz) conforming to IEC 60068-2-6
shock resistance	30 gn (duration = 11 ms) conforming to IEC 60068-2-27
IP degree of protection	IP67 conforming to IEC 60529

Offer Sustainability


Not Green Premium product	Not Green Premium product
Compliant - since 0924 - Schneider Electric declaration of conformity	Compliant - since 0924 - Schneider Electric declaration of conformity
Reference not containing SVHC above the threshold	Reference not containing SVHC above the threshold
WARNING: This product can expose you to chemicals including:	WARNING: This product can expose you to chemicals including:
Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and	Diisononyl phthalate (DINP), which is known to the State of California to cause cancer, and
Di-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm.	eDi-isodecyl phthalate (DIDP), which is known to the State of California to cause birth defects or other reproductive harm.
For more information go to www.p65warnings.ca.gov	For more information go to www.p65warnings.ca.gov

Contractual warranty

Warranty period	18 months
-----------------	-----------


Dimensions

Receiver dimensions



- (1) LEDs
- (2) Potentiometer

Transmitter dimensions




Mounting and Clearance

Fixing nut tightening torque: 15 N.m Connector tightening torque: 2 N.m

Wiring Schemes




Receiver




R max. < 800 Ω (Ue = 24 V), < 300 Ω (Ue = 12 V)

Beam Break Test (only on Transmitter)

Beam made




Beam broken




Sensor Connector Pin View

Transmitter



(a) Test


Receiver



- (a) Analogue output
- (b) Solid-state output


Operation, Settings

Type, opacity of objectAnalogue output curveSwitching level of digital solid-statePNP output



- (a) Degree of opacity of object
- (b) Potentiometer set at minimum
- (c) Potentiometer set at maximum
- (y) Output current
- (x) Degree of opacity of object

Type, opacity of objectAnalogue output curveSwitching level of digital solid-statePNP output



- (a) Degree of opacity of object
- (b) Potentiometer set at minimum
- (c) Potentiometer set at maximum
- (y) Output current
- (x) Degree of opacity of object